



NOTES:

1. INSTALLATION SHALL COMPLY WITH TITLE 17 REQUIREMENTS, COUNTY HEALTH REGULATIONS AND WATER DEPARTMENT STANDARDS.
2. DEVICE MUST BE FROM THE CURRENT USC APPROVED LIST AND PAINTED WITH TWO COATS OF RUSTOLEUM, COLOR APPROVED BY CITY ENGINEER.
3. INSTALL DUMP PORT AT A MINIMUM OF 12" ABOVE GRADE.
4. ENCLOSURE TO PROVIDE MINIMUM 12" CLEARANCE AROUND UNIT.
5. TAP AND METER INSTALLATION CONDUCTED BY CITY PERSONNEL.
6. PROVIDE 6" CLEARANCE TO EDGE OF CONCRETE FROM FENCING.
7. WRAP ALL METAL PIPE BELOW GRADE WITH .010" x 2" P.E. TAPE. USE HALF LAP.
8. GATE VALVE LIDS MUST NOT BE LOCATED UNDER SLAB.
9. DEVICE TO BE TESTED BY AN APPROVED TESTER AND TAGGED PRIOR TO APPROVAL FOR USE.
10. PROTECTION AGAINST INCLIMATE WEATHER OPTIONAL BY OWNER.
11. GATE VALVE TO BE MILWAUKEE 105 SERIES/ MALLABLE IRON HAND WHEEL.



City of San Bruno
Standard Detail

BACKFLOW PREVENTER

CITY ENGINEER:

APPROVED BY: WING WONG

R.C.E. C35688

DATE: AUG 2011

DRAWN BY: JMH

W-03

DETAIL NO: