



NOTE:

1. SEE STD. DWG SS-02 FOR SEWER CLEANOUT AND EXTENSION BEYOND PROPERTY LINE.
2. LOCATION OF SEWER LATERAL SHALL HAVE AT LEAST 1' VERTICAL AND 10' HORIZONTAL CLEAR SEPARATION FROM ANY WATER SERVICE.
3. MATERIAL FOR SEWER LATERAL SHALL BE PVC, HDPE OR DIP. SEE STANDARD SPECIFICATION FOR MATERIAL REQUIREMENT.

DEEP SEWER - GREATER THAN 10'



City of San Bruno
Standard Detail

SEWER LATERAL

DATE: AUG 2011

DRAWN BY:

CITY ENGINEER:

APPROVED BY:

WING WONG

R.C.E. C35688

SS-06

DETAIL NO: